

**HW-15a****Exemption 6 - PII**

	Analyte		Result	Trigger
	Arsenic	Wellhead	5.1 ug/L	4.5 ug/L
	Arsenic	Wellhead - filtered	4.3 ug/L	
	Arsenic	Tap	3.3 ug/L	
	Arsenic	Tap - filtered	2.8 ug/L	
	Sodium	Wellhead	16,900 ug/L	20,000 ug/L
	Sodium	Wellhead - filtered	16,200 ug/L	
	Sodium	Tap	64,600 ug/L	
	Sodium	Tap - filtered	66,000 ug/L	
EPA Alt. Water	No			
Cabot Alt. Water	?			
Treatment	?			
Proposed EPA Water	?			
Proposed 2nd Sampling	?			

**HW-16****Exemption 6 - PII**

	Analyte		Result	Trigger
	Barium	Wellhead	2910 ug/L	2900 ug/L
	Barium	Wellhead - DUP	2890 ug/L	
	Barium	Wellhead - filtered	2870 ug/L	
	Barium	Wellhead - filtered DUP	3040 ug/L	
	Barium	Tap	2850 ug/L	
	Barium	Tap - filtered	2860 ug/L	
	Sodium	Wellhead	50,200 ug/L	20,000 ug/L
	Sodium	Wellhead - DUP	50,000 ug/L	
	Sodium	Wellhead - filtered	49,500 ug/L	
	Sodium	Wellhead - filtered DUP	52,000 ug/L	
	Sodium	Tap	50,200 ug/L	
	Sodium	Tap - filtered	49,500 ug/L	
EPA Alt. Water	No			
Cabot Alt. Water	?			
Treatment	?			
Proposed EPA Water	?			
Proposed 2nd Sampling	?			

**HW-22****Exemption 6 - PII**

	Analyte		Result	Trigger
	Arsenic	Wellhead	7.1 ug/L	4.5 ug/L
	Arsenic	Wellhead - filtered	1 ug/L	
	Arsenic	Tap	3.8 ug/L	
	Arsenic	Tap - filtered	1.2 ug/L	
	Chromium	Wellhead	4.9 ug/L	3.1 ug/L
	Chromium	Wellhead - filtered	2 ug/L	
	Chromium	Tap	2.5 ug/L	
	Chromium	Tap - filtered	2 ug/L	
	Lead	Wellhead	22.7 ug/L	15 ug/L
	Lead	Wellhead - filtered	1 ug/L	
	Lead	Tap	8.1 ug/L	
	Lead	Tap - filtered	1 ug/L	
	Manganese	Wellhead	635 ug/L	320 ug/L
	Manganese	Wellhead - filtered	361 ug/L	
	Manganese	Tap	460 ug/L	
	Manganese	Tap - filtered	313 ug/L	
EPA Alt. Water	No			
Cabot Alt. Water	?			
Treatment	?			
Proposed EPA Water	?			
Proposed 2nd Sampling	?			

**HW-31****Exemption 6 - PII**

	Analyte		Result	Trigger
	Sodium	Wellhead	26,700 ug/L	20,000 ug/L
	Sodium	Wellhead - DUP	26,700 ug/L	
	Sodium	Wellhead - Filtered	25,800 ug/L	
	Sodium	Wellhead - filtered DUP	27,000 ug/L	
	Sodium	Tap	25,500 ug/L	
	Sodium	Tap - filtered	26,200 ug/L	
	Sodium			
EPA Alt. Water	No			
Cabot Alt. Water	?			
Treatment	?			
Proposed EPA Water	?			
Proposed 2nd Sampling	?			

**HW-47****Exemption 6 - PII**

		<b>Analyte</b>		<b>Result</b>	<b>Trigger</b>
		Arsenic	Wellhead	90.7 ug/L	4.5 ug/L
		Arsenic	Wellhead - filtered	94.2 ug/L	
		Arsenic	Tap	91.1 ug/L	4.5 ug/L
		Arsenic	Tap - filtered	90.2 ug/L	
		Manganese	Wellhead	947 ug/L	320 ug/L
		Manganese	Wellhead - filtered	877 ug/L	
		Manganese	Tap	1 ug/L	
		Manganese	Tap - filtered	1 ug/L	
		Sodium	Wellhead	53,600 ug/L	
		Sodium	Wellhead - filtered	56,400 ug/L	
		Sodium	Tap	93,900 ug/L	
		Sodium	Tap - filtered	93,600 ug/L	
EPA Alt. Water		No			
Cabot Alt. Water		No			
Treatment		No			
Proposed EPA Water		No			
Proposed 2nd Sampling		Yes			